2025 ANNUAL DRINKING WATER QUALITY REPORT

PWSID #: 6200043 NAME: Saegertown Borough

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report, or concerning your water utility, please contact Greg Rademacher or Chuck Lawrence at 814-763-4600. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the second Monday of each month at 6:00 p.m. at the Borough Building. Please call ahead to be placed on the agenda.

SOURCE(S) OF WATER:

Our water sources are: Multiple wells located in Saegertown Borough and Hayfield Township.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

Monitoring Your Water:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2025. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS:

Action Level (AL) **-** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) - The minimum level of residual disinfectant required at the entry point to the distribution system.

Level 1 Assessment – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter (µg/L)

ppm = parts per million, or milligrams per liter (mg/L)

ppq = parts per quadrillion, or picograms per liter

ppt = parts per trillion, or nanograms per liter (ng/L)

DETECTED SAMPLE RESULTS:

Chemical Contaminants								
Contaminant	**MCL in CCR Units**	**MCLG**	**Level Detected**	**Range of Detections**	**Units**	**Sample Date**	**Violation Y/N**	**Sources of Contamination**
Arsenic (ppb)	10	0	3.00	3.00-3.90	ppb	5/7/2024	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium	2	2	0.0221	0.0221-0.308	ppm	5/7/2024	N	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Nitrate	10	10	1.25	1.25-1.95	ppm	7/01/2025	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Di(2-ethylhexyl)phthalate	6	0	4.00	4.00	Ppb	4/1/2025	N	Discharge from rubber & chemical factories

Perfluorooctanoic acid (PFOA)	14	5	6.7	0.00-6.7	ppt	2/04/2025-10/07/2025	N	Drinking water containing PFOA in excess of the MCL of 14 ng/L may cause adverse health effects, including developmental effects (neurobehavioral and skeletal effects)
Perfluorooctanesulfonic acid (PFOS)	18	14	275	1.00-275	ppt	2/4/2025-10/7/2025	Y	Drinking water containing PFOS in excess of the MCL of 18 ng/L may cause adverse health effects, including decreased immune response.
Trihalomethanes	80	N/A	0	0.00-25.10	ppb	9/17/2025	N	By-products of drinking water chlorination
Chlorine (Distribution)	MRDL=4	MRDLG=4	0.74	0.58-0.74	ppm	Twice/monthly	N	Water additive used to control microbes

*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health.

Entry Point Disinfectant Residual

Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine (Entry Point 100)	0.50	0.50	0.50-1.11	ppm	2/20/2025	N	Water additive used to control microbes.
Chlorine (Entry Point 101)	0.70	0.70	0.70-1.13	ppm	3/13/2025	N	Water additive used to control microbes.
Chlorine (Entry Point 102)	0.40	0.41	0.41-1.95	ppm	5/21/2025	N	Water additive used to control microbes.
Chlorine (Entry Point 103)	0.60	.93	0.93-1.97	ppm	2/9/2025	N	Water additive used to control microbes.
Chlorine (Entry Point 104)	0.40	0.40	0.40-0.94	ppm	3/22/2025	N	Water additive used to control microbes.
Chlorine (Entry Point 105)	0.40	0.40	0.40-0.83	ppm	3/13/2025	N	Water additive used to control microbes.

Lead and Copper

Contaminant	Action Level (AL)	MCLG	90th Percentile Value	Range of tap sampling results	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	1.36	1.36	ppb	0	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.098	0.098	ppm	0	N	Corrosion of household plumbing.

Microbial (related to E. coli)							
33	**MCL**	**MCLG**	**Positive Sample(s)**	**Violation Y/N**	**Sources of Contamination**		
E. coli	Routine and repeat samples are total coliform-positive **and** either is *E. coli*-positive **or** system fails to take repeat samples following *E. coli*-positive routine sample **or** system fails to analyze total coliform-positive repeat sample for *E. coli.*	0	N	N	Human and animal fecal waste.		
Contaminants	**TT**	**MCLG**	**Assessments/ Corrective Actions**	**Violation Y/N**	**Sources of Contamination**		
E. coli	Any system that has failed to complete all the required assessments **or** correct all identified sanitary defects, is in violation of the treatment technique requirement	N/A	See description under "Detected Contaminants Health Effects Language and Corrective Actions" section	N	Human and animal fecal waste.		

VIOLATIONS: *See the section under "Other Information" PFOS/PFOA*

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

Information about Lead

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Saegertown Borough is responsible for providing high quality drinking water and is removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Saegertown Borough and 814-763-4600. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at *http://www.epa.gov/safewater/lead*.

OTHER INFORMATION:

What are PFOS and PFOA?

PFOS and PFOA are chemicals that are part of a larger group referred to as perfluoroalkyl substances (PFAS). These chemicals are manmade and do not occur naturally in the environment. Because these chemicals have been used in a number of consumer products, most people have been exposed to them. The chemicals stability of PFOS and PFOA also makes them very persistent in the environment.

PFOA/PFOS: This is not an immediate risk. If it had been, you would have been notified immediately. However, exposure to PFOS and PFOA over certain levels may result in adverse health effects, including developmental effects to fetuses during pregnancy or to breastfed infants (e.g. low birth weight, accelerated puberty, skeletal variations), cancer (e.g. testicular, kidney), liver effects (e.g. tissue damage), immune effects (e.g. antibody production and immunity), thyroid effects and other effects (e.g. cholesterol changes) The EPA calculates health

advisory levels to offer a margin or protection against adverse health effects to the most sensitive populations: fetuses during pregnancy and breastfed infants.

The Borough prepared a service line inventory of our system that includes the type of materials contained in each service line in our distribution system. This inventory can be accessed by contacting our office at 814-763-4600.

We at SAEGERTOWN BOROUGH work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.